



## **ELECTRICAL APPLIANCE TEST & INSPECTION REPORT**

### **SATURN SOUND SYSTEMS**

**44 HIGH STREET  
SUTTON  
ELY  
CAMBRIDGESHIRE  
CB6 2RB**

**14 November 2017**

**Head Office and National Control Centre:  
11 Crab Marsh  
Wisbech  
Cambridgeshire  
PE13 3JG**

**Telephone: 0800 84 888 22  
Fax: 01945 738 001  
[e-mail: service@purepat.com](mailto:service@purepat.com)**



# Electrical Portable Appliance Inspection & Testing

## **ELECTRICAL SAFETY ADVICE**

Thank you for choosing NSS Pure-PAT to carry out your Electrical Portable Appliance Testing.

Please be aware that although we have Inspected and Tested the appliances on the enclosed Test & Inspection schedule there are still further precautions you should take to minimise the risk of any appliance causing a fire or electric shock.

- **IMPORTANT: Integrity of Fixed Electrical Wall Sockets**

Part of the PAT Testing procedure is to test the earth continuity of appliances that require to be continuously earthed. The earth continuity of an appliance is a very important built in safety feature that should take away the risk of a person receiving a shock should the appliance develop an electrical fault.

This safety feature can only work correctly providing the earth connection to the fixed wall socket is also properly connected otherwise there is a risk of an electric shock even if the actual appliance has been passed as safe.

Fixed wall sockets can have as many as 17 different fault combinations, therefore if you have not had the wall sockets tested within the past three years we would recommend that they are tested on our next visit. If you require any help or advice please contact us.

- **Remember Water and Electricity are not a safe combination!**

In areas such as kitchens and staff rooms it is imperative that water does not come into contact with any electrical current – always ensure that your hands are dry before connecting or switching on any electrical appliance – this includes the sockets and switches that are mounted on the wall.

- **Extension Leads**

Extension leads that are used in the workplace should have a Residual Current Device (RCD) permanently fitted if the extension lead is more than 15 metres in length.

Do not use high energy Fan Heaters or Radiators in multi-socket extension leads – the maximum combined wattage of all appliances in multi-socket extension leads should not exceed 3000 watts.

It is not good practice to have extension leads sited on floors or anywhere near where water or liquid has a high risk of spillage.

Coiled extension leads generate heat – the greater the coil the greater the heat. Coiled extension leads should NOT be used continuously - far better to have a made to measure or fully unwound lead than a coiled lead.

- **FAILED or Damaged Appliances**

On NO account should you continue to use any damaged or faulty electrical appliances that have failed our tests – you are risking the possibility of a fire or electric shock.

The above are just a small sample of measures that can be taken to ensure the safety of everyone who comes into contact with electrical appliances.



CERTIFICATE OF  
ELECTRICAL APPLIANCE TESTING

CERTIFICATE NO:  
17/1411

**SATURN SOUND SYSTEM**  
**44 HIGH STREET**  
**SUTTON**  
**ELY**  
**CAMBRIDGESHIRE**


This certificate confirms that the Portable Electrical Appliances that are listed on the enclosed test records and have Pure-PAT identification labels attached to the appliance at the above named premises have been formally Inspected, Checked and Tested for Electrical Safety using the guidelines as required by the Health & Safety Executive (HSE) and taking into account the requirements of the Health & Safety at Work Act 1974, the provision and Use of Work Equipment Regulations 1998 and the Electricity at Work Regulations 1989.

**CERTIFICATE VALID UNTIL 14 NOVEMBER 2018**

  
AUTHORISED SIGNATORY

NSS Pure-PAT Electrical Testing  
11 Crab Marsh  
Wisbech, Cambs PE13 3JG  
Tel: 01945 738151  
E-mail: [service@purepat.com](mailto:service@purepat.com)

# PORTABLE APPLIANCE TESTING REPORT

	<b>NSS Pure-PAT Electrical Testing</b> 11 Crab Marsh, Wisbech, Cambridgeshire PE13 3JG Telephone: 01945 738151 e-mail: service@purepat.com	<b>NO:</b>	17/1411	SATURN SOUND SYSTEM 44 HIGH STREET SUTTON ELY CAMBRIDGESHIRE CB6 2RB
	<b>DATE:</b>	14 November 2017		

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
22025	PIN SPOTS		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22026	PIN SPOTS		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22027	XLITE SPEAKER		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22028	XLITE SPEAKER		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22029	XLITE SPEAKER		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22030	XLITE SPEAKER		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22031	EUROLIVE POWERED SPEAKER		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22032	EUROLIVE POWERED SPEAKER		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22033	EUROLIVE POWERED SPEAKER B815		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22034	EUROLIVE POWERED SPEAKER B815		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22035	EUROLIVE POWERED SPEAKER B14000		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22036	EUROLIVE POWERED SPEAKER		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22037	EUROLIVE POWERED SPEAKER		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22038	EUROLIVE POWERED SPEAKER		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22039	EUROLIVE POWERED SPEAKER B14000		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22040	KALEIDO LIGHT		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22041	KALEIDO LIGHT		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22042	HAZE MACHINE		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22043	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22044	AC POWER SUPPLY UNIT MIC		2	PASS		PASS	PASS	14-Nov-18	PASS	
22045	STAR CLOTH		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22046	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22047	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22048	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22049	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22050	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22051	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22052	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22053	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22054	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22055	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22056	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22057	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22058	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22059	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
22060	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22061	MECA TRIPAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22062	MARTIN WIZARD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22063	POWER CON LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22064	MARTIN WIZARD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22065	POWER CON LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22066	SPHERION		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22067	SPHERION		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22068	POWER BATTON		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22069	GENESIS SCAN		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22070	GENESIS SCAN		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22071	GENESIS SCAN		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22072	GENESIS SCAN		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22073	TECHICS 1210		2	PASS		PASS	PASS	14-Nov-18	PASS	
22074	TECHICS 1210		2	PASS		PASS	PASS	14-Nov-18	PASS	
22075	2000 NEXUS 1		2	PASS		PASS	PASS	14-Nov-18	PASS	
22076	2000 NEXUS 2		2	PASS			PASS	14-Nov-18	PASS	
22077	2 CORE POWER LEAD IEC POWER LEAD		2	PASS		PASS	PASS	14-Nov-18	PASS	
22078	DJM 900		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22079	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22080	CDJ 2000		2	PASS		PASS	PASS	14-Nov-18	PASS	
22081	2 CORE POWERLEAD IEC POWER LEAD		2	PASS		PASS	PASS	14-Nov-18	PASS	
22082	CDJ 2000NSX2		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22083	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22084	UV BAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22085	UV BAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22086	UV BAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22087	UV BAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22088	UV BAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22089	UV BAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22090	UV BAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22091	UV BAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22092	UV BAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22093	UV BAR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22094	2 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22095	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22096	LAPTOP POWER SUPPLY UNIT		2	PASS		PASS	PASS	14-Nov-18	PASS	
22097	AC POWER SUPPLY UNIT		2	PASS		PASS	PASS	14-Nov-18	PASS	
22098	SHOW DIRECTOR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22099	SHOW DIRECTOR CONTROL		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22100	4 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22101	TAGCAM POWER SUPPLY UNIT		2	PASS		PASS	PASS	14-Nov-18	PASS	
22102	6200 EQUALISER		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
22103	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22104	COMPRESSOR LIMITER 2600		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22105	COMPRESSOR LIMITER 4600		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22106	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22107	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22108	YAMAHA MG20 X4		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22109	4 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22110	4 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22111	6 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22112	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22113	DENON CD 4500		2	PASS		PASS	PASS	14-Nov-18	PASS	
22114	BEHRINGER GRAPHIC IS02		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22115	BEHRINGER GRAPHIC IS02		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22116	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22117	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22118	BEHRINGER MDX 2600		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22119	BEHRINGER MDX 4600		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22120	BEAM 2 MTG 24		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22121	BEAM 2 MTG 24		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22122	4 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22123	4 GANG SURGED		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22124	2 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22125	30 METER EXTENSION REEL		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22126	4 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22127	2 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22128	2 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22129	LONG IEC POWER LEAD 5 METER EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22130	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22131	2 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22132	1 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22133	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22134	2 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22135	2 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22136	6 GANG EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22137	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22138	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22139	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22140	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22141	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22142	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22143	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22144	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22145	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
22146	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22147	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22148	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22149	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22150	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22151	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22152	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22153	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22154	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22155	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22156	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22157	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22158	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22159	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22160	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22161	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22162	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22163	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22164	IEC POWER LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22165	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22166	IEC EXTENSION/SPLITTER		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22167	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22168	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22169	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22170	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22171	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22172	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22173	IEC SPLITTER		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22174	IEC SPLITTER		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22175	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22176	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22177	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22178	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22179	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22180	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22181	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22182	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22183	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22184	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22185	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22186	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22187	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22188	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	

ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
22189	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22190	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22191	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22192	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22193	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22194	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22195	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22196	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22197	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22198	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22199	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22200	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22201	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22202	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22203	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22204	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22205	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22206	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22207	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22208	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22209	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22210	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22211	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22212	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22213	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22214	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22215	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22216	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22217	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22218	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22219	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22220	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22221	IEC EXTENSION LEAD		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22222	IEC POWER LEAD TO 13 AMP		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22223	BALL ROTATOR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22224	3 WAY ADAPTOR		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22225	16AMP EXTENSION LEAD TO 14M		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22226	16AMP EXTENSION LEAD TO 14M		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22227	16AMP TO 13AMP		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22228	16AMP TO 13AMP		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22229	16AMP TO 13AMP 2 GANG		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22230	16AMP TO 13AMP 2 GANG		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	
22231	16AMP TO 4G SURGE		1	PASS	PASS	PASS	PASS	14-Nov-18	PASS	



ID NO.	DESCRIPTION	LOCATION	CLASS	VISUAL INSPECT	TEST		Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH	INSULATION				
22232	16AMP TO 6G SURGE		1	PASS	PASS	PASS	PASS	14-Nov-18	<b>PASS</b>	

<b>PASSED</b>	<b>208</b>
<b>FAILED</b>	<b>0</b>
<b>TOTAL</b>	<b>208</b>